



CITY OF WAUWATOSA  
**BUILDING & SAFETY DIVISION**  
7725 WEST NORTH AVENUE, WAUWATOSA, WISCONSIN 53213

PHONE (414) 479-8907

FACSIMILE (414) 479-8986

DAVID M. WHEATON  
CHIEF BUILDING OFFICIAL

E-MAIL: [tbuilding@wauwatosa.net](mailto:tbuilding@wauwatosa.net)

WEB SITE: [www.wauwatosa.net](http://www.wauwatosa.net)

**BOARD OF EXAMINERS & APPEALS AGENDA**  
**FRIDAY, MARCH 12, 2010**  
**9:00 A.M. IN COMMITTEE ROOM #1**

Item 1.

9200 West Wisconsin Avenue - Mr. Curtis Baer has requested a variance to locate wall mounted fire alarm appliances 168 inches above finished floor whereas the maximum height allowed above finished floor is 96 inches. Reference NFPA 72-2002:7.5.4.

\*Under Wisconsin Statutes 19.85(1)(a) or (g) the Board may adjourn into executive session for purposes of deliberating after a quasi-judicial hearing or to confer with their legal counsel. Subsequent to the executive session, the Board may reconvene in open session for further consideration of other matters on the agenda.

Any person who has a qualifying disability as defined by the Americans With Disabilities Act that requires the meeting or materials at the meeting to be in an accessible location or format must contact the City Clerk at voice telephone 479-8917, TTY 471-8484, or by mail to: City of Wauwatosa, City Clerk, 7725 West North Avenue, Wauwatosa, Wisconsin 53213. Requests for accommodations for meetings should be made at least three (3) business days prior to the meeting. Every effort will be made to arrange accommodations for all meetings, so please give the City Clerk as much advance notice as possible.

Notices sent to: Board Members, Applicants, Interested Parties, Alderpersons, Publications, Administration, Mayor, Attorney, Building Inspectors, Planning, WEDC, Police Department, Clerk